



HALL CORP PTY LTD AC/N 066 449 769 A.B.N 34 149 057 182 ATF HALL FAMILY TRUST TA
 P.O. BOX 7760, GARBUIT B.C. Q., 4814, PHONE: (07) 4774 7888, FAX: (07) 4774 7677
 ses01@bigpond.com

Sodium Sulphate Soundness Report

Client : Burdekin Transport Services Address : 5-11 Mackenzie Street, Ayr , 4807 Project Name : Compliance Testing Project Number : TS18729 Location: Burdekin River , Ayr	Report Number: TS18729 - 13/1 Report Date : 15/12/2015 Order Number : Test Method : AS1141.24 <p style="text-align: right;">Page 1 of 1</p>
---	---

Sample Number :	B78625			
Test Number :				
Sampling Method :	As Received			
Date Sampled :	1/12/2015			
Date Tested :	3/12/2015			
Material Type :	Sand			
Material Source :	Ayr Plant			
Lot Number :				
Sample Location :	Stockpile : Ayr Plant Sample: 1 Type: Sand			
Percent Loss 26.5mm (%) :	0			
Percent Loss 16mm (%) :	0			
Percent Loss 13.2mm (%) :	0			
Percent Loss 8mm (%) :	0			
Percent Loss 6.7mm (%) :	0			
Percent Loss 3.35mm (%) :	0			
Percent Loss 850µm (%) :	0.2			
Percent Loss 1.70mm (%) :	0.3			
Percent Loss 425µm (%) :	0.3			
Percent Loss 212µm (%) :	0.5			
Sodium Sulphate Soundness (%) :	0.3			
Remarks :				

<p style="text-align: center;">Accredited for compliance with ISO/IEC 17025.</p>	<p style="text-align: center;">APPROVED SIGNATORY</p> <p style="text-align: center;">Leigh Newman - Supervisor NATA Accreditation Number 2856</p>
---	---